


Notes:

- 1) Recirculation loop by others.
- 2) Not for construction.
- 3) Expansion tank must be located after check valve.
- 4) Locate injection tee in last storage tank

NOT FOR CONSTRUCTION

| | | | |
|---|---------|--|--------------|
|  | | Fort Worth, TX 76134 Blauvelt, NY 10913 | |
| <h2>2 Tank + Recirc</h2> | | | |
| DRWN. BY | DATE | DWG. NO: | REV. |
| BJC | 3/27/23 | SD-L-1262 | C |
| | | | Page 2 of 60 |