


Notes:

- 1) Recirculation loop by others.
- 2) Not for construction.
- 3) Expansion tank must be located after check valve.
- 4) Locate injection tee in last storage tank

NOT FOR CONSTRUCTION

		Fort Worth, TX 76134 Blauvelt, NY 10913	
<h3>4 Tank + Recirc</h3>			
DRWN. BY	DATE	DWG. NO:	REV.
BJC	3/27/23	SD-L-1264	C
			Page 2 of 60