



TOP VIEW

NOTES:

- 1) ALL DIMENSIONS SHOWN ARE IN INCHES (MILLIMETERS).
- 2) CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY LYNC. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.
- 3) RECOMMENDED CLEARANCE ENSURES FULL PERFORMANCE. MINIMUM CLEARANCE WILL RESULT IN DECREASED AIRFLOW AND HEATING CAPACITY AT COLDER TEMPERATURES.



Blauvelt, NY
Fort Worth, TX

AEGIS A 350-500
MULTI UNITS CLEARANCE DRAWING

DWN. BY K.S. DATE 092623
SCALE NTS
REV. BY _____ DATE _____

SD-L-1336

REV.
A