



Pipe Temp.	Line Type
CW	
HW	
Recirc	
Tempered	

	T&P RELIEF VALVE
	PUMP
	MIXING VALVE
	BALL VALVE
	CHECK VALVE
	BALANCE VALVE
	DRAIN
	DIFFUSER TEE

- NOTES:
- 1) NOT FOR CONSTRUCTION
  - 2) RECIRCULATION LOOP BY OTHERS
  - 3) COLD WATER EXPANSION TANK MUST BE LOCATED AFTER CHECK VALVE
  - 4) LOCATE DIFFUSER TEE IN LAST STORAGE TANK

		Fort Worth, TX 76134 Blauvelt, NY 10913	
<b>BOLT MINI – RECIRC. + 2 TANKS          INSTALLATION</b>			
DRWN. BY <u>BJJ</u>	DATE <u>12/4/25</u>	DWG. NO: <u>SD-L-1372</u>	REV. <u>A</u>